



# TEST REPORT

우 31035 충남 천안시 서북구 직산읍 직산로 136 충남테크노파크  
종합지원센터 1202호

TEL (041)589-0010

FAX (041)589-0012

성적서번호 : TAN-003240

접 수 일 자 : 2016년 05월 24일

대 표 자 : 이석우

시험완료일자 : 2016년 07월 01일

업 체 명 : 한국하니소(주)

주 소 : 충청남도 당진시 송악읍 부곡공단1길 70

시 료 명 : ISOVER WEATHERPROOF 40K(이소바 웨더프루프 40K)

## 시험결과

시험항목	단위	시료구분	결과치	시험방법
장기흡수율	kg/m <sup>2</sup>	-	0.35	ISO 16535 : 2012

\* 용 도 : 품질관리용

- 비 고 : 1. 이 성적서는 의뢰자가 제시한 시료 및 시료명으로 시험한 결과로써 전체 제품에 대한 품질을 보증하지 않으며, 성적서의 진위확인인 홈페이지(www.ktr.or.kr) 또는 QR code로 확인 가능합니다.  
2. 이 성적서는 홍보, 선전, 광고 및 소송용 등으로 사용될 수 없으며, 용도 이외의 사용을 금합니다.  
3. 이 성적서는 원본(등본 포함)만 유효하며, 사본 및 전자 인쇄본/파일본은 결과치 참고용입니다.

*Park Joo-ick*

작성자 : 박주익  
E-mail: jooick@ktr.or.kr

*You Seok*


기술책임자 : 유석  
Tel : 1577-0091(ARS ①→④)

2016년 07월 01일

**KTR** 한국화학융합시험연구원



위변조 확인용 QR code



# TEST REPORT

136, Jiksan-ro, Jiksan-eup, Seobuk-gu, Cheonan-si, Chungcheongnam-do, TEL 82-41-589-0010 FAX 82-41-589-0012  
31035 Rep. of KOREA

Report No : TAN-003240

Receipt Date : May.24.2016

Client : Lee Seoku

Test Completion Date : Jul.01.2016

Hankuk Haniso Co.,Ltd.

70, Bugokgongdan 1-gil, , Dangjin-si, Chungcheongnam-do, Rep. of  
KOREA

Sample : ISOVER WEATHERPROOF 40K

## TEST RESULTS

TEST ITEM	UNIT	SAMPLE	RESULT	TEST METHOD
Long term water absorption	kg/m <sup>2</sup>	-	0.35	ISO 16535 : 2012

\* USAGE : QUALITY CONTROL

NOTE : 1. The test results on this test report are only limited to the samples and sample names provided by the customer and KTR does not guarantee the quality of all products of the customer, and you can confirm the authenticity of the test report online ([www.ktr.or.kr](http://www.ktr.or.kr)) or by using the QR code.  
2. This test report shall not be used for public relation, advertisement, lawsuit and any other purposes outside the scope of its defined usage.  
3. Only original copy (including certified copy) of the test report is valid – electronic copy (hard and/or soft) is for your reference only.

*Park Joo-ick*

Prepared by Park Joo-ick  
E-mail: jooick@ktr.or.kr

*You Seok*

Reviewed by You Seok  
Technical Manager  
Tel: 1577-0091(ARS ①→④)

Jul.01.2016

**Korea Testing & Research Institute**

President

*Choi Hyeonka*



QR Code to verify genuineness

1 of Total 1 Page(s)